

Addendum 1

Issued March 12, 2020

The following information changes the RFT documents issued on February 27, 2020

GENERAL INFORMATION

Item 1: Grguric Architects Incorporated Addendum dated March 11, 2020. (1 page)

QUESTIONS AND RESPONSES

Q1 The City of Hamilton Building Department has recently informed us that there are new standards and requirements for fire alarm verification as of 2020. Can you please indicate which inspections and reports would be by the contractor and which would be performed by and paid for by HWDSB directly.

R1 See General Information Item 1.

Q2 Is this project open bid or for prequalified contractors?

R2 This competitive process is posted to the open market.

Q3 This refer to note C5 shown on drawing A2.10. It states: "Patch prime and paint existing concrete block al all removed chalkboard and tackboards and millwork to match existing condition". Please clarify if wall areas to be visible are required to have masonry joints repointed to receive new finish and paint.

R3 This will be addressed during construction should it turn out that repointing of the block is required.

End of Addendum 1

ARCHITECTURAL

Item 1 Specifications **Section 08800 Glazing**
Part 2, paragraph 2.1 Material
DELETE item 4 "Fire Rated Glass (FG)"

Item 2 Specifications **Section 09660 Resilient Tile Flooring and Rubber Base**
Part 2, paragraph 2.1 Materials
Under item 2 "Luxury Vinyl composition tile (LVT)" **ADD** "Dura LVT Contract" by Interflor" as acceptable equivalent.

Question 1

The City of Hamilton Building Department has recently informed us that there are new standards and requirements for fire alarm verification as of 2020. Can you please indicate which inspections and reports would be by the contractor and which would be performed by and paid for by HWDSB directly.

Response 1

The electrical contractor is responsible for providing and paying for all 3rd party fire alarm verifications required by the City of Hamilton Building Department. As the permit for this project was issued before the revisions to the fire alarm verification requirements came into effect. The verification requirements found in the electrical specification shall be applied.

END OF ADDENDUM