

Addendum 2

Issued March 13, 2020

The following information changes the RFT documents issued on February 27, 2020

CLOSING DATE CHANGE

Change of closing date to Wednesday April 8, 2020, on or before 2:00:00 PM local time.
Submission Label attached (1 page).

Due to the Ministerial Order issued March 12, 2020, HWDSB will not be in a position to accept any tender packages prior to Monday April 6, 2020. Please coordinate deliveries and couriers accordingly.

GENERAL INFORMATION

Item 1: Refer to RFT document, Introduction and Project Details. REMOVE and REPLACE Section 4 Project Schedule with below.

1. The Successful Bidder will adhere to section GC 3.5 in regard to milestone dates set below.
2. The following are Project milestone dates:
 - a) Tender Issued Thursday February 27, 2020
 - b) Site Walkthrough on or before 3:00pm Tuesday March 3, 2020
 - c) Closing for Questions Tuesday March 10, 2020
 - d) Tender Closing on or before 2:00 PM Wednesday April 8, 2020
 - e) Anticipated Construction Commencement for the Learning Commons (room 132) and the Science classroom (room 145) Monday May 4, 2020
 - f) Anticipated Construction Commencement for the windows, playfield and Art room (room 142) Thursday July 2, 2020
 - g) Substantial Performance Friday August 21, 2020
 - h) Total Completion/Occupancy Friday September 4, 2020

Item 2: Grguric Architects Incorporated Addendum dated March 13, 2020. (1 page)

Addendum 2

QUESTIONS AND RESPONSES

Q1 Privacy film type (Note C13 on drawing A2.10)

R1 See General Information Item 2.

Q2 Is it full coverage privacy film?

R2 See General Information Item 2.

Q3 The windows called to be replaced may or may not be cast into the block/brick and we cannot know until we start to remove. If cast into the block/brick this is much more labour intensive to remove and will require much more patching of the block walls around the frames in order to accept new frames. Do we price as though the windows were cast into the block?

R3 See General Information Item 2.

Q4 Would HWDSB consider an email submission? We are asking do to the concern around COVID-19. Many people/companies are taking the precaution due to the COVID-19; they are trying to help flatten the curve and prevent social contact if and when possible.

R4 At this time, we will not be changing submission requirements.

End of Addendum 2

Addendum 2

SUBMISSION LABEL

IMPORTANT: This envelope template will be used for returning Submissions

From: _____

Contact: _____

Telephone: _____

Deliver to: Manager of Procurement and Risk Management
Hamilton-Wentworth District School Board
20 Education Court
Hamilton, ON L9A 0B9
Main Lobby Reception Desk
Tender Box

Sealed Document for:

Reference No.: RFT 2020-130-P01394

Description: RFT – Flamborough Centre- Window Renewal and Classroom
Renovations

Closing Date and Time: Wednesday April 8, 2020 on or before 2:00:00 PM

FOR OFFICE USE ONLY

<p>Place Time Stamped Label Here</p>	<p>Receiver's Initials</p>
--------------------------------------	----------------------------

ARCHITECTURAL

- Item 1 Specifications **Section 01020 Cash Allowances**
2. Cash Allowance
Item 13. **ADD** sub-item "3. Interior Window Film"
-

Question 1

The windows called to be replaced may or may not be cast into the block/brick and we cannot know until we start to remove. If cast into the block/brick this is much more labour intensive to remove and will require much more patching of the block walls around the frames in order to accept new frames. Do we price as though the windows were cast into the block?

Response 1

The existing window frames are recessed into the void between the interior concrete block and exterior veneer brick by approximately 38mm at the window head and jambs. The existing window frames are to be removed completely and the voids to be filled in as per details 1/A4.20 and 3/A4.20. These details are typical for all of the windows except for the windows found in Rooms 134, 135, 139 and 140.

END OF ADDENDUM